

January 01, 2015
The City of Elyria's
Requirements for Vendors that need water hook-ups for Festivals and
Community Events

Proper Back-Flow Protection SHALL be on any Mobile Unit.

Proper Back-Flow Protection SHALL be on Carbonated Post Mix Machines.

Water tanks and reserve water tanks shall be empty upon arrival.

Only Food Grade Hose will be allowed for water hook-up.

While the Vendor is setting up, Chlorine Residual tests will be done.

General inspections will be done to check for proper back-flow installations.

If water filters are used, they must be new for the current calendars year's usage.